



Product Service

Attestation of Conformity

No. N8 14 05 87139 001

Holder of Certificate: DONGGUAN TAGUAN ELECTRONICS CO., LTD.GaoXin Technology Area, HuJing Avenue, HouJie Town
523945 DongGuan City, GuangDong
PEOPLE'S REPUBLIC OF CHINA**Product:** Power supplies
(LED DRIVER)**Model(s):** AMS-1339-A, AMS-1339-B, AMS-1339-C, AMS-1341-A,
AMS-1341-B, AMS-1341-C, AMS-3119-A, AMS-3119-B,
AMS-3119-C, AMS-3139-A, AMS-3139-B, AMS-3139-C**Parameters:**
Rated Input : 100-240VAC, 50/60Hz, 0.25A
Rated Output : See page 2 for details
Protection Class : II
Degree of Protection : IP20
Method of Installation: Independent
Type of Output : Constant current type
ta, tc : See page 2 for details**Tested according to:** EN 61347-2-13:2006
EN 61347-1/A2:2013
EN 62493:2010

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 651401302001
(Alex Kong)**Date,** 2014-06-11**CE** After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2

Attestation of Conformity
No. N8 14 05 87139 001



Product Service

Model	Rated output Voltage (VDC)	Rated output Current (mA)	Max. output Voltage (VDC)	tc/ta (°C)
AMS-1339-A	20-28	350	34.0	75/50
AMS-1339-B	9-18	550	26.5	
AMS-1339-C	6-14	700	21.5	
AMS-1341-A	25-36	350	42.0	
AMS-1341-B	15-24	550	28.0	
AMS-1341-C	9-18	700	26.0	
AMS-3119-A	35-45	350	49.0	
AMS-3119-B	18-28	550	33.5	
AMS-3119-C	12-22	700	26.6	
AMS-3139-A	45-54	350	62.5	80/50
AMS-3139-B	24-34	550	40.0	
AMS-3139-C	18-26	700	31.0	