



Product Service

Attestation of Conformity

No. N8 14 05 87139 003

Holder of Certificate: DONGGUAN TAGUAN ELECTRONICS CO., LTD.GaoXin Technology Area, HuJing Avenue, HouJie Town
523945 DongGuan City, GuangDong
PEOPLE'S REPUBLIC OF CHINA**Product:** Power supplies
(LED DRIVER)**Model(s):** AMS-3144-A, AMS-3144-B, AMS-3144-C,
AMS-3199-A, AMS-3199-B, AMS-3199-C

Parameters:	Rated Input :	100-240VAC, 50/60Hz, 0.35A
	Rated Output :	See page 2 for details
	Protection Class :	II
	Degree of Protection :	IP20
	Method of Installation:	Independent
	Type of Output :	Constant current type
	ta :	50°C
tc :	70°C	

Tested according to: EN 61347-2-13:2006
EN 61347-1/A2:2013
EN 62493:2010

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 651401302101

Date, 2014-06-11

(Alex Kong)



After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2

Attestation of Conformity
No. N8 14 05 87139 003

Product Service

Model	Rated output Voltage (VDC)	Rated output Current (mA)	Max. output Voltage (VDC)
AMS-3144-A	60-70	350	77.5
AMS-3144-B	35-45	550	49.0
AMS-3144-C	25-35	700	38.0
AMS-3199-A	45-54	500	58.5
AMS-3199-B	28-38	700	43.5
AMS-3199-C	18-26	1050	32.7